



# City of Danville, Virginia

PO Box 3300  
Danville, VA 24543

427 Patton Street, Rm 304  
Danville, VA 24541

J. Gary Via, CPPO  
Director of Purchasing  
e-mail: [viajg@danvilleva.gov](mailto:viajg@danvilleva.gov)

Phone: (434) 799-6528  
Fax: (434) 799-5102  
e-mail: [purchasing@danvilleva.gov](mailto:purchasing@danvilleva.gov)

## ADDENDUM #3

---

PROJECT NAME:	Doyle Thomas Park Splashpad
PROJECT # (CITY):	IFB-22-23-046
PROJECT # (SITE COLLAB):	19100.03
ADDENDUM ISSUE DATE:	December 12, 2022
ISSUED BY:	Graham H. Smith, PLA @ Site Collaborative and Carol Henley, Acting Director of Purchasing @ City of Danville

---

### **PRIOR ADDENDUMS:**

ADDENDUM #1 – dated November 22, 2022  
ADDENDUM #2 – dated December 1, 2022

### **NOTICE TO BIDDERS:**

The Contract Documents for the above-referenced Project are modified as set forth in this Addendum. The original Contract Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Contract Documents. Bidder shall take this Addendum into consideration when preparing and submitting a bid.

This is Addendum #3. It has to be recognized as noted within the PROPOSAL FORM and the signature page from this form has to be signed and returned with the PROPOSAL FORM.

### **ADDENDUM CONTENTS:**

- Additional/Updated Bid Documents
- Bid Document Revisions and/or Clarifications (specifications)
- Bid Document Revisions and/or Clarifications (drawings)
- Bidder Questions Responses (questions received via email)
- Signature Page (acknowledging receipt of this addendum)

---

### **ADDITIONAL/UPDATED BID DOCUMENTS (see attached PDF sheets)**

None at this time

### **BID DOCUMENTS REVISIONS and/or CLARIFICATIONS (specifications):**


None at this time

**BID DOCUMENTS REVISIONS and/or CLARIFICATIONS (drawings):**

None at this time

**BIDDER QUESTIONS RESPONSES (FOR ALL QUESTIONS RECEIVED IN WRITING THROUGH [PARKBIDS@DANVILLEVA.GOV](mailto:PARKBIDS@DANVILLEVA.GOV) THROUGH 5pm ET ON 12/9/22)**

Q1: See Image Below for Question:



*RESPONSE: Those notes are typical for the Splashpad area as a whole as needed, but yes specifically for the Splashpad area. They are shown on the sheet as a general callout and are only referencing the splashpad.*

Q2: The concrete specifications call for 20% fly ash in all mixes. Will 25% fly ash be acceptable? This will save time and money on lab testing. (This change was recently approved in Addendum 4 for the Riverfront Park Project).

*RESPONSE: Yes, this change to 25% fly ash is acceptable.*

*Carol Henley*

**SIGNATURE AND ACKNOWLEDGEMENT:**

Company Name: \_\_\_\_\_ Signature: \_\_\_\_\_

Company Address: \_\_\_\_\_ Printed Name: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_ Title: \_\_\_\_\_

Date: \_\_\_\_\_ Email Address: \_\_\_\_\_ Phone Number: \_\_\_\_\_

**END OF ADDENDUM #3 (no attachments)**